
LITHIUM ION IRON PHOSPHATE BATTERY SYSTEMS

MODEL NUMBER: GT12V525A-F1915-DIN-MODULE

EXTERNAL BMS VERSION





EXTERNAL BMS REQUIRED

BMS SOLD SEPARATELY. SEE BMS DATA SHEET PROVIDED BY LITHIONICS BATTERY®.

| Item | | Description |
|---|---|---|
| Model | | GT12V525A-8D-DIN-MODULE |
| Nominal Voltage | | 12.8 |
| Nominal Capacity | | 525 |
| Nominal Watt Hours | | 6720 |
| Internal Resistance | | <300 milliohms |
| Charge | | |
| Charging temperature range | | 32F/0C to 113F/45C |
| Charge voltage | | 14.6 |
| Recommended float charge voltage(for standby use) | | 13.4 |
| Recommended max charge current* | | 262.5 |
| Allowed max charge current* | | 400 |
| Discharge | | |
| Discharging temperature range | | -4F/-20C to 131F/55C |
| Operating Voltage Range | | 11.6 to 13.4 |
| Recommended max discharge current* | | 400 |
| Max discharge current* | | 400 |
| Pulse discharge current | | 5250 |
| Discharge cut-off voltage | | NeverDie® Power Reserve @ 12.00 Low-Voltage Cut-Off @11.60 |
| Mechanical | | |
| Dimensions | | Length 19.0" |
| | | Width 15.0" |
| | | Height 11.99" |
| Weight | | Approx. 133lbs (60.3kg) |
| Storage | | |
| Storage Temperature & Humidity Range | < 1 Month | -4~95°F (-20~35°C), 45~75%RH |
| | < 3 Months | 14~86°F (-10~30°C), 45~75%RH |
| | Recommended storage | 59~95°F (15~35°C), 45%RH~75%RH |
| Long Term Storage | If the battery needs to be stored for > 3 months the voltage should be 13.2V (50%5OC), and stored at the recommended storage specifications shown above. Additionally, the battery needs at least one charge & discharge cycle every six months | |
| Self-discharge rate | Residual capacity | ≤3% per month; ≤15% per year |
| | Reversible capacity | ≤1.5%per month; ≤8% per year |







ENERGY

525 AMP HOURS PULSE AMPS: 5250 (1SEC)

6720 WATT-HOURS

1. LITHIUM BATTERIES ARE NOT DESIGNED FOR CHARGING IN SUB-FREEZING TEMPERATURES. CONTACT LITHIONICS BATTERY® FOR DETAILS ON OUR COLD WEATHER PACKAGE. 2. INSTALLATION: IT IS RECOMMENDED THAT BATTERIES BE INSTALLED CABLE OR TERMINAL SIDE UP.

WARNING

NOTE: CONTACT LITHIONICS BATTERY® FOR A USER INSTALLATION GUIDE & STORAGE PROCEDURES. FOLLOW THE GUIDE TO ENSURE FITNESS OF USE & WARRANTY. 12V GT SERIES

WWW.LITHIONICSBATTERY.COM

REV.D