LITHIONICS BATTERY®

LITHIUM ION IRON PHOSPHATE BATTERY SYSTEMS



MODEL NUMBER: GT51V150A-F24-DIN-MODULE-UL


EXTERNAL BMS VERSION



| Item | | Description |
|---|--|--|
| Model | | GT51V150A-F24-DIN-MODULE-UL |
| Nominal Voltage | | 51.2 |
| Nominal Capacity | | 150 |
| Nominal Watt Hours | | 7680 |
| Internal Resistance | | <300 milliohms |
| Charge | | · |
| Charging temperature range | | 32F/0C to 113F/45C |
| Charge voltage | | 58.4 |
| Recommended float charge voltage(for standby use) | | 53.6 |
| Recommended max charge current* | | 75 |
| Allowed max charge current* | | 150 |
| Discharge | | |
| Discharging temperature range | | -4F/-20C to 131F/55C |
| Operating Voltage Range | | 46.4 to 53.6 |
| Recommended max discharge current* | | 150 |
| Max discharge current* | | 225 |
| Pulse discharge current | | 1500 |
| Discharge cut-off voltage | | NeverDie® Power Reserve @ 48.00 Low-Voltage Cut-Off @46.4 |
| Mechanical | | - |
| Dimensions | | Length 24.0" |
| | | Width 13.0" |
| | | Height 11.1" |
| Weight | | Approx. 160lbs (72.6kg) |
| Storage | | , , , , , |
| Storage Temperature & | < 1 Month | -4~95°F (-20~35°C), 45~75%RH |
| Humidity Range | < 3 Months | 14~86°F (-10~30°C), 45~75%RH |
| | Recommended storage | 59~95°F (15~35°C), 45%RH~75%RH |
| Long Term Storage | If the battery needs to be stored for > 3 months the voltage should be 13.2V (50%SOC), and stored at the recommended storage specifications shown above. Additionally, the battery needs at least one charge & discharge cycle every six months. | |
| Self-discharge rate | Residual capacity | ≤3% per month; ≤15% per year |
| | Reversible capacity | ≤1.5%per month; ≤8% per year |



BATTERY®.



150 AMP HOURS

PULSE AMPS: 1500 (1 SEC)

7680 WATT-HOURS

WARNING

1. LITHIUM BATTERIES ARE NOT DESIGNED FOR CHARGING IN SUB-FREEZING TEMPERATURES. CONTACT LITHIONICS BATTERY® FOR DETAILS ON OUR COLD WEATHER PACKAGE. 2. INSTALLATION: IT IS RECOMMENDED THAT BATTERIES BE INSTALLED CABLE OR TERMINAL SIDE UP.

NOTE: CONTACT LITHIONICS BATTERY® FOR A USER INSTALLATION GUIDE & STORAGE PROCEDURES. FOLLOW THE GUIDE TO ENSURE FITNESS OF USE & WARRANTY.

