
THIONICS BATT LITHIUM ION IRON PHOSPHATE BATTERY SYSTEMS ERY®

MODEL NUMBER: GT48V150A-F24-DIN-MODULE

EXTERNAL BMS VERSION





EXTERNAL BMS REQUIRED

BMS SOLD SEPARATELY. SEE BMS DATA SHEET PROVIDED BY LITHIONICS **BATTERY®.**

Item		Description
Model		GT48V150A-F24-DIN-MODULE
Nominal Voltage		48
Nominal Capacity		150
Nominal Watt Hours		7200
Internal Resistance		<300 milliohms
Charge		
Charging temperature range		32F/0C to 113F/45C
Charge voltage		54.75
Recommended float charge voltage(for standby use)		50.25
Recommended max charge current*		75
Allowed max charge current*		150
Discharge		
Discharging temperature range		-4F/-20C to 131F/55C
Operating Voltage Range		43.5 to 50.25
Recommended max discharge current*		150
Max discharge current*		225
Pulse discharge current		1500
Discharge cut-off voltage		NeverDie® Power Reserve @ 45.00 Low-Voltage Cut-Off @43.5
Mechanical		
Dimensions		Length 24.0"
		Width 13.0"
		Height 11.1"
Weight		Approx. 155lbs (70.3kg)
Storage		
Storage Temperature	< 1 Month	-4~95°F (-20~35°C), 45~75%RH
& Humidity Range	< 3 Months	14~86°F (-10~30°C), 45~75%RH
	Recommended storage	59~95°F (15~35°C), 45%RH~75%RH
Long Term Storage	If the battery needs to be stored for > 3 months the voltage should be 49.5V (50%SOC), and stored at the recommended storage specifications shown above. Additionally, the battery needs at least one charge & discharge cycle every six months.	
Self-discharge rate	Residual capacity	≤3% per month; ≤15% per year
	Reversible capacity	≤1.5%per month; ≤8% per year
* Maximum charging and dis	charging rates apply depending upo	n the ambient temperature and duty cycle of the system.







1. LITHIUM BATTERIES ARE NOT DESIGNED FOR CHARGING IN SUB-PREZING TEMPERATURES. CONTACT LITHIONICS BATTERY® FOR DETAILS ON OUR COLD WEATHER PACKAGE. 2. INSTALLATION: IT IS RECOMMENDED THAT BATTERIES BE INSTALLED CABLE OR TERMINAL SIDE UP

WARNING

12.00

NOTE: CONTACT LITHIONICS BATTERY® FOR A USER INSTALLATION GUIDE & STORAGE PROCEDURES. FOLLOW THE GUIDE TO ENSURE FITNESS OF USE & WARRANTY.



1.00

4.47

REV.B